

Letter of Attestation

According to
Low Voltage Directive 2014/35/EU

Product:	Aurora Intelligent AC charging pile				
Name of the applicant:	Wanbang Digital Energy Co., Ltd.				
Address of the applicant:	No.39, Longhui Road, Wujin National Hi-Tech Industrial Development District, Changzhou, Jiangsu, China				
Name of the manufacturer:	Wanbang Digital Energy Co., Ltd.				
Address of the manufacturer:	No.39, Longhui Road, Wujin National Hi-Tech Industrial Development District, Changzhou, Jiangsu, China				
Ratings and principal characteristics:	Model / Type Ref.	DH-AC0070XG70	DH-AC0070XG71	DH-AC0110XG70	DH-AC0110XG71
	Nominal input voltage (Vac):	230 Vac	230 Vac	230/400 Vac	230/400 Vac
	Nominal input frequency (Hz):	50 Hz	50 Hz	50 Hz	50 Hz
	Max. continuous output current (A):	32 A	32 A	16 A	16 A
	Nominal output power (W):	7 kW	7 kW	11 kW	11 kW
	Operating ambient temperatures:	-30 °C to +50 °C	-30 °C to +50 °C	-30 °C to +50 °C	-30 °C to +50 °C
	Protective class:	Class I	Class I	Class I	Class I
	Ingress protection (IP):	IP55	IP54	IP55	IP54
Trade Mark (if any):	 Star Charge®				
Model / Type Ref.:	DH-AC0070XG70, DH-AC0070XG71, DH-AC0110XG70, DH-AC0110XG71				
Tested according to:	EN 61851-1:2019				

Date: April 6, 2021	Signature:..... 
Ref. Certif. No.: 80053355 (Project No.: 80076777)	

THIS LETTER OF ATTESTATION DOES NOT AUTHORIZE THE USE OF THE CSA MARK ON THE SUBJECT PRODUCTS.

QUOTATIONS FROM THE TEST REPORT OR THE USE OF THE NAME CSA GROUP OR ITS REGISTERED TRADEMARK, IN ANY WAY, IS NOT PERMITTED WITHOUT PRIOR WRITTEN CONSENT OF CSA GROUP TESTING & CERTIFICATION INC.